


APR 21 2009

NEW CUSTOMER ID / OUTLET ID:26210045 OLD ~~OUTLET~~ DESIGNATION:26210003[illegible]

DATE	4/20/2009
------	-----------



Water Discharge Calculation Sheet

ST. MARY'S HOSPITAL (PBI)

MARCH 2009

Total water used from meter reading (Cubic feet)	642,300
x 7.48 (gallons / cubic foot)	
Total Usage (Gallons)	4,804,404
Evaporation (Gallons) 5% evaporation *	0
Volume Discharged (Gallons)	4,804,404

Volume Discharged For Month	
Daily Average Discharge (Gallons)	154,981
Daily Maximum Discharge (Gallons)	170,479

Month 3
Last day 31

* NOTE: In the months of January, February and March the PVSC DOES NOT ALLOW a reduction for evaporation.

70027224 Meter 1	70027225 Meter 2	70029946 Meter 3	60144298 Meter 4	Total	x 100	x 7.48
1,155	4,156	992	120	6,423	642,300	4,804,404
Reading Date						
Meter 1	3/13/09		CF1	CF2	Consumption (100 cu.ft.)	
	3/13/09		5,207.00	1,599.00		
			<u>4,052.00</u>	<u>1,599.00</u>		
		C - L	1,155.00	0.00		
			<u>x 1</u>	<u>x 100</u>		
			1,155.00	0.00	1,155.00	
Meter 2	3/13/09		1,893.00	1,457.00		
	3/13/09		<u>637.00</u>	<u>1,428.00</u>		
		C - L	1,256.00	29.00		
			<u>x 1</u>	<u>x 100</u>		
			1,256.00	2,900.00	4,156.00	
Meter 3	3/13/09		9,964.00	7,830.00		
	3/13/09		<u>9,142.00</u>	<u>7,813.00</u>		
		C - L	822.00	17.00		
			<u>x 1</u>	<u>x 10</u>		
			822.00	170.00	992.00	
Meter 4	3/13/09		2,485.00			
	3/13/09		<u>2,473.00</u>			
		C - L	12.00			
			<u>x 10</u>			
			120.00		120.00	